



Total Quality. Assured.

Suzhou Kisinhom Machinery Equipment Co., Ltd.

LIMITED PRODUCTION CERTIFICATION REPORT

SCOPE OF WORK

Limited Production Certification of control panel, type model is D2001.

REPORT NUMBER

200400065SHA-001

ISSUE DATE

10th -April-2020

PAGES

3

DOCUMENT CONTROL NUMBER

SFT-ETL LPC-OP-19c (28-July-2017)

© 2017 INTERTEK



LIMITED PRODUCTION CERTIFICATION REPORT

Report Number	200400065SHA-001	Original Issued:	8th -April-2020	Revised:	None
----------------------	------------------	-------------------------	-----------------	-----------------	------

Standard(s)	Industrial Control Panels [UL 508A:2018 Ed.3+R:03Jul2018] NFPA 79 Issued: 2014/05/19 -Version 2015-Electrical Standard for Industrial Machinery
--------------------	--

Applicant	Suzhou Kisinom Machinery Equipment Co., Ltd.	Manufacturer	Suzhou Kisinom Machinery Equipment Co., Ltd.
Address	No. 168 Huangpujiang RD (south), DINGSHANHU, KUNSHAN, JIANGSU	Address	No. 168 Huangpujiang RD (south), DINGSHANHU, KUNSHAN, JIANGSU
Country	China	Country	China
Contact	Mr. ZHANG ZHIGUO	Contact	Mr. ZHANG ZHIGUO
Phone	133 9087 8665	Phone	133 9087 8665
FAX	0512-55132371	FAX	0512-55132371
Email	352064176@qq.com	Email	352064176@qq.com

Product Description	
Product	Control panel
Brand name	NA
Description	The products covered by this report are control panel used for the manufacture equipment.
Models	D2001
Model Similarity	NA
Ratings	480V, 60Hz, 500A
Other Ratings	NA

Labeling						
Model	Serial No.	LPC No.		Model	Serial No.	LPC No.
D2001	JXH-155	1034318				
D2001	JXH-156	1034319				

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

LIMITED PRODUCTION CERTIFICATION REPORT

Test Summary			
Evaluation Period	2020/04/02~2017/04/02		Project No. 200400065SHA
Sample Rec. Date	2020/04/02	Condition Prototype	Sample ID. NA
Test Location	Building NO.86, 1198 Qinzhou Road (North), Caohejing Development Zone, Shanghai, China		
Test Procedure	Testing Lab		
Determination of the result includes consideration of measurement uncertainty from the test equipment and methods. The product was tested as indicated below with results in conformance to the relevant test criteria.			
The following tests were performed:			
Test Description	NFPA 79 Electrical Standard for Industrial Machinery 2015 edition	Industrial Control Panels [UL 508A:2018 Ed.3+R:03Jul2018] Clause	
Dielectric strength test	18,4	--	
Grounding continuity test	18.2	--	

Conclusion			
A representative sample of the product covered by this report has been evaluated and found to comply with the applicable requirements of the standards indicated above.			
Please note, this Report does not represent authorization for the applicant or manufacturer to apply Intertek Certification Marks.			
Completed by:	Kevin Zhu	Reviewed by:	Frank Song
Title:	Certification Engineer	Title:	Technical Manager
Signature:		Signature:	